

## Q 3 SAK10

**Weidmüller Interface GmbH & Co. KG**

Klingenbergstraße 26  
D-32758 Detmold  
Germany

[www.weidmueller.com](http://www.weidmueller.com)



The distribution or multiplication of a potential to adjoining terminal blocks is realized via a cross-connection. Additional wiring effort can be easily avoided. Even if the poles are broken out, contact reliability in the terminal blocks is still ensured. Our portfolio offers pluggable and screwable cross-connection systems for modular terminal blocks.

### General ordering data

|            |   |
|------------|---|
| Version    | Cross-connector (terminal), when screwed in, grey, 57 A, Number of poles: 3, Pitch in mm (P): 9.90, Insulated: No, Width: 26.8 mm |
| Order No.  | <a href="#">0457200000</a>  |
| Type       | Q 3 SAK10   |
| GTIN (EAN) | 4008190135379   |
| Qty.       | 50 items  |

## Q 3 SAK10

Weidmüller Interface GmbH &amp; Co. KG

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com

## Technical data

## Approvals

ROHS Conform

## Dimensions and weights

|            |         |                 |             |
|------------|---------|-----------------|-------------|
| Depth      | 20.5 mm | Depth (inches)  | 0.8071 inch |
| Height     | 6 mm    | Height (inches) | 0.2362 inch |
| Width      | 26.8 mm | Width (inches)  | 1.0551 inch |
| Net weight | 8.36 g  |                 |             |

## Temperatures

Storage temperature -25 °C...55 °C Ambient temperature -5 °C...40 °C

## Environmental Product Compliance

RoHS Compliance Status Compliant without exemption  
REACH SVHC No SVHC above 0.1 wt%

## Material data

Basic material CuSn Colour grey

## System specifications

Version for cross-connection link

## Additional technical data

Type of fixing when screwed in Installation advice Direct mounting  
Explosion-tested version No

## Dimensions

Pitch in mm (P) 9.90 mm

## General

Number of poles 3 Installation advice Direct mounting

## Rating data

Nominal current 57 A

## Classifications

|             |             |             |             |
|-------------|-------------|-------------|-------------|
| ETIM 8.0    | EC000489    | ETIM 9.0    | EC000489    |
| ETIM 10.0   | EC000489    | ECLASS 14.0 | 27-25-03-03 |
| ECLASS 15.0 | 27-25-03-03 |             |             |