



Main

Range of product	ComPacT NSX400...630 new generation ComPacT NSX400...630
Device short name	VigiPacT
Product or component type	Vigi add-on
Device application	Wiring
Range compatibility	ComPacT new generation ComPacT NSX400 new generation circuit breaker ComPacT new generation ComPacT NSX630 new generation circuit breaker ComPacT ComPacT NSX400 circuit breaker ComPacT ComPacT NSX630 circuit breaker
Poles description	3P
[In] rated current	400 A 630 A
Earth-leakage protection class	Class A Class AC
Residual earth-leakage sensitivity adjustment type	Adjustable
Earth-leakage sensitivity	0.03 A for class A 0.1 A for class A 0.3 A for class A 0.5 A for class A 1 A for class A 3 A for class A 10 A for class AC 30 A for class AC
Residual earth-leakage time delay adjustment type	Adjustable
[Δt] residual earth-leakage time delay adjustment	0 Ms 60 Ms 150 Ms 300 Ms 500 Ms 800 Ms 1.2 S 4 s

Complementary

Network type	AC
Network frequency	50/60 Hz
[Ue] rated operational voltage	440...550 V AC 50/60 Hz conforming to IEC 60947-2
Earth-leakage protection	With
Maximum breaking time	800 ms
Overvoltage category	IV

Environment

Electrical shock protection class	Class II
Standards	IEC 60947-2

Packing Units

Unit Type of Package 1	PCE
Number of Units in Package 1	1
Package 1 Height	14.0 cm
Package 1 Width	17.0 cm
Package 1 Length	19.5 cm
Package 1 Weight	2.696 kg
Unit Type of Package 2	S04
Number of Units in Package 2	6
Package 2 Height	30.0 cm
Package 2 Width	40.0 cm
Package 2 Length	60.0 cm
Package 2 Weight	16.866 kg

Offer Sustainability

Sustainable offer status	Green Premium product
REACH Regulation	REACH Declaration
EU RoHS Directive	Compliant with Exemptions
Mercury free	Yes
China RoHS Regulation	China RoHS Declaration
RoHS exemption information	Yes
Environmental Disclosure	Product Environmental Profile
Circularity Profile	End Of Life Information
WEEE	The product must be disposed on European Union markets following specific waste collection and never end up in rubbish bins
California proposition 65	WARNING: This product can expose you to chemicals including: Lead and lead compounds, which is known to the State of California to cause cancer and birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov